

- 1. FLOORSTANDS HAS BEEN DESIGNED TO WITHSTAND A MAX. SEISMIC LOAD OF 1.0 G'S (UBC ZONE 4, Z=0.4).
 2. ANCHORS MUST BE EMBEDDED AT LEAST 3 1/2 "INTO THE STRUCTURAL SLAB.
 3. SPECIAL INSPECTION OF THE ANCHOR BOLTS IS REQUIRED FOR ALL SEISMIC SPECIFICATIONS GREATER THAN 0.5 G'S.
 4. SUPPORTED UNIT MUST BE FASTEN OR WELDED TO FLOORSTAND AS REQ'D. PER CODES TO MEET SEISMIC RATING.
- 5. TURNING VANE IS SHIPPED LOOSE AND MAY REQUIRE SOME FIELD CUT DURING FIELD INSTALLATION
- 6. DIMENSION IS FROM INSIDE (EDGE TO EDGE) OF ATTACHMENT PLATES
- 7. B.O. = BY OTHERS (NOT BY THE VMC GROUP)
- 8. FRAME SHALL BE PAINTED THE VMC GROUP CÓLOR.
- 9. INSTALL PER INSTALLATION INSTRUCTION FORM 8020011.

OTHER MATERIALS, COMPOUNDS, OR FINISHES WITH EQUAL OR SUPERIOR PROPERTIES MAY BE SUBSTITUTED AS THEY BECOME AVAILABLE.

CERTIFIED FOR:			SCALE: NONE	4 0 Mg b
JOB NAME:	MODEL FLOORSTAND ISOLATED SEISMIC SPRING WITH AEQM STYLE ISOLATOR		SHEET:	'' VISCMA
CUSTOMER:				
CUSTOMER P.O.:			DRAWING NO.:	REVISION
SALES ORDER:		Bloomingdale, NJ 07403 Houston, TX 77041		