



CERTIFIED FOR: JOB NAME: CUSTOMER: **CUSTOMER P.O.:**

SALES ORDER:

MODEL M2H-1R 4200-28000 LBS. SPRING ISOLATORS WITH **EXTERNAL ADJUSTMENT** 1 INCH DEFLECTION



SHEET: 1 OF 2

SCALE:

NONE

Bloomingdale, NJ 07403 Houston, TX 77041

120R-101804 REV.:8 3/2/22 REV. DESCRIPTION DATE READ INSTRUCTIONS IN THEIR ENTIRETY BEFORE BEGINNING. LOCATE ISOLATORS UNDER EQUIPMENT AFTER DETERMINING POSITIONS DESIGNATED IN THE VMC GROUP SUBMITTAL, SHEET 1. 2. ALL LIMIT BOLTS ARE FACTORY SET AND BONDED IN PLACE. THE SHIPPING NUT ON THE LIMIT BOLT MUST BE LOWERED UNTIL IT TOUCHES THE BOLT HEAD. THE NUT WAS SHIPPED IN THE RAISED POSITION. DO NOT ATTEMPT TO READJUST THE LIMIT BOLTS. FACTORY SETTING ASSURES UNIFORM BOLT LOADING IF UPLIFT **EQUIPMENT SUPPORT BEAM** OCCURS. AS IN THE CASE OF A COOLING TOWER BEING DRAINED. 3. THE VMC GROUP RECOMMENDS BOLTING ALL ISOLATORS TO A FLAT SURFACE. WHEN A WEIGHT CHANGE OCCURS IN EXCESS OF 20% OF -ADJUSTING NUT AND WASHER EQUIPMENT OPERATING WEIGHT, THE ISOLATOR BASE PLATE MUST REMOVABLE ADJUSTING BOLT (2 TYP) BE BOLTED. THE LOAD MUST BE CENTERED ON THE ISOLATOR TO (2 TYP)-AVOID ECCENTRIC LOADING OF TOP PLATE, WHICH WOULD TILT THE TOP PLATE OF THE ISOLATOR. THE TOP PLATE OF THE ISOLATOR MUST BE UNIFORMLY LOADED ACROSS ENTIRE LENGTH OF TOP PLATE OR THE EQUIPMENT MUST BE BLOCKED UNTIL LOAD IS STEEL SHIM TRANSFERRED TO THE ISOLATOR. THE VMC GROUP MUST BE ADVISED BEFORE THE ISOLATORS ARE RELEASED FOR 3/8 -PRODUCTION TO EVALUATE ANY VARIANCE TO THESE REQUIREMENTS. (AFTER 4. WHEN THE APPLICATION IS OUTDOORS AND THE EQUIPMENT WILL ADJUSTMENT) BE SUBJECT TO HIGH WINDS, THE OWNER'S REPRESENTATIVE MUST EVALUATE ANCHOR TYPE AND SIZE TO EFFECTIVELY RESIST WIND SHIPPING NUT FORCES. TYPE M2H ISOLATORS ARE RESTRICTED TO LOW SEISMIC AND WIND APPLICATIONS, STEEL ATTACHMENT ONLY. USE VMC LIMIT-STOP BOLT GROUP TYPE MS ISOLATORS TO ISOLATE EQUIPMENT THAT WILL BE SUBJECT TO SEISMIC AND WIND FORCES WITH CONCRETE ATTACHMENT. ISOLATORS ARE SHIPPED TO THE JOB SITE WITH SHIMS BETWEEN THE TOP PLATE AND HOUSING. THESE SHIMS MUST BE IN PLACE WHEN ISOLATOR IS POSITIONED UNDER EQUIPMENT. 6. THE ADJUSTMENT PROCESS CAN ONLY BEGIN AFTER FULL OPERATING WEIGHT IS REACHED. THE ADJUSTMENTS CAN BE MADE BY STARTING AT ANY ISOLATOR AND TURNING THE ADJUSTING NUT CLOCKWISE TWO TURNS. PROCEED AROUND THE EQUIPMENT TO EACH ISOLATOR, ADJUSTING EACH TWO TURNS TO COMPRESS THE SPRINGS UNIFORMLY. CONTINUE THIS ADJUSTING PROCESS UNTIL ONE ISOLATOR JUST RISES OFF THE SHIMS. STOP ADJUSTMENT ON THAT AND OTHER ISOLATORS AS THEY RISE OFF THE SHIMS 3/4 DIA HOLE APPROXIMATELY 1/32". WHEN ALL ISOLATORS HAVE RISEN ABOVE (4 TYP) THE SHIMS, THE ADJUSTMENT PROCESS IS COMPLETE. REMOVE 7. FURTHER ATTENTION TO THE INSTALLATION IS NOT NORMALLY REQUIRED. THE VMC GROUP SUGGESTS A SEMIANNUAL INSPECTION OF THE COMPONENTS FOR POSSIBLE CORROSION PROBLEMS. IF PROBLEMS ARE OBSERVED, CONSULT THE VMC GROUP OR CORROSION CONTROL EXPERTS TO RECTIFY THE PROBLEM. IF THE SPRING PACKAGE MUST BE REMOVED, CONTACT A FACTORY OTHER MATERIALS, COMPOUNDS, OR FINISHES WITH EQUAL OR SUPERIOR PROPERTIES MAY BE SUBSTITUTED AS THEY BECOME AVAILABLE. REPRESENTATIVE FOR DETAILED PROCEDURE.



٠	ER	TI				\frown	п	
	ᄄ		ГΙ	EL	, ,	U	ĸ	Ξ

JOB NAME:

CUSTOMER:

CUSTOMER P.O.

SALES ORDER:

MODEL M2H-1R 4200-28000 LBS. SPRING ISOLATORS WITH **EXTERNAL ADJUSTMENT** 1 INCH DEFLECTION



THE POWER OF TOGETHER Bloomingdale, NJ 07403 Houston, TX 77041

NONE	Memt	
SHEET:	***- VIS	
2 OF 2		
DRAWING NO.:		REVISION

PROPRIETARY: EXCEPT AS OTHERWISE AGREED IN WRITING. THE INFORMATION AND DESIGN DISCLOSED HEREIN ARE THE PROPERTY OF THE VMC GROUP AND MUST NOT BE COPIED OR DISTRIBUTED OUTSIDE THE VMC GROUP EXCEPT TO AUTHORIZED PERSONS WITH A GENUINE NEED TO KNOW WHO BY THE USE HEREOF ACKNOWLEDGE THE VMC GROUP'S OWNERSHIP AND AGREE TO MAINTAIN THIS INFORMATION AND DESIGN IN STRICT CONFIDENCE