
154R-105049 REV.:5 | 12/22/22 REV. DESCRIPTION DATE BY

KIT PART NUMBER	CABLE LENGTH (FT.)	CABLE COLOR	MAX. TENSION ALLOWABLE (LBS.)	KIT TYPE
SB-125-LRC-410	10	ORANGE	1100	9/16" SLOT / 1/2" STAKE EYE
SB-125-LRC-407	7	ORANGE	1100	9/16" SLOT / 1/2" STAKE EYE

- RATING AT 45° FOR STEEL ATTACHMENT (LRFD)
- RATING AT 45° FOR CONCRETE ATTACHMENT- 1/2" HILTI TZ @2-1/2" EMBEDMENT, 4" SLAB MIN



- QTY (2) Ø1/2" STAKE EYE BRACKETS PREASSEMBLED WITH 1/8" ORANGE CABLE (SEE TABLE FOR LENGTH) & QTY (2) SB-125 Ø9/16" SLOTTED BRACKETS WITH EACH BRACKET ASSEMBLY COMPRISED OF (2) 1/2" BOLTS & (2) 1/2" SERRATED LOCK NUTS.
- 4. FIELD TORQUE 1/2" LOCK NUTS TO 35 FT-LBS.
- 5. FM APPROVAL APPLIES ONLY TO INSTALLATIONS USING STRUT.

OTHER MATERIALS, COMPOUNDS, OR FINISHES WITH EQUAL OR SUPERIOR PROPERTIES MAY BE SUBSTITUTED AS THEY BECOME AVAILABLE.



SB-125 BRACKET Ø9/16 SLOT

EQUIPMENT ATTACHMENT

CERTIFIED FOR:

JOB NAME: CUSTOMER:

EQUIPMENT

LOOP CABLE

HEAD OF BOLT

UNDER & AROUND

CUSTOMER P.O.

SALES ORDER

MODEL SB-125-LRC 1100 LBS. 1/8 INCH ORANGE SEISMIC CABLE RESTRAINT KIT



THE POWER OF TOGETHER

Bloomingdale, NJ 07403 Houston, TX 77041

SCALE:					
NONE	Memi				
SHEET:	*** **	C WH			
DRAWING NO.:		REVISIO			